

Office of the Medical Superintendent, Shahpur,
Muzaffarnagar

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

O.C.H.C./Safe Drink water & Sanitation/2025/26/214

Date. 19/05/25

It is certificate that an inspection team headed
by Dr. D.P. Jaiswal MO/C SHAHPUR Inspected the
THE GREEN PUBLIC SCHOOL (BUDHANA) MZN. on
Dated _____ and found that school has Safe Drinking Water & Sanitization
facilities for the student and members of staff of the institution and is
maintaining the hygienic sanitation condition in the school building & the campus
as per the norms described by the state Govt.

The above valid for a period of 0-1 yr.

Signature with seal: _____

Name: _____

Designation _____

विक्रिता अधीक्षक

सामुदायिक स्वास्थ्य केंद्र

शहपुर जिला मुजफ्फरनगर

To, Principal

The Green public school
Budhana MZN.

PRINCIPAL
The Green Public School
Budhana Muzaffarnagar

Manager
The Green Public School
Budhana (MZN.)

Safe drinking water and sanitary condition certificate

No

dated

It is certified that an inspection team headed by from *Fare Labs* PHED inspected the The Green Public School, Bhasana, Budhana (Muzaffarnagar) on date *14/6/2025* and on the basis of Water Test Report (Attached) bearing no. *19/6/2025* dated of PHED lab certified that The Green Public School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the C

Central/ State Government

This certificate is valid till

Name of Officer *ALOK RANJAN*

Designation *Executive officer*

Name and address of office: *Nagar Panchayat, Budhana, (Muzaffarnagar)*

Pc
अधिसासी अधिकारी
नगर पंचायत-बुढाना
जनपद-मुजफ्फरनगर

To
The Green Public School
Basana, Budhana (Muzaffarnagar)

Zaker Ali

Manager
The Green Public School
Budhana (MZN.)

[Signature]
PRINCIPAL
The Green Public School
Budhana Muzaffarnagar

FARELABS

Science | Technology | Innovation

FARE LABS Private Limited (Testing Division)

Location 1 (Permanent Facility)

L-17/3, DLF Phase-II, IFFCO Chowk,

M.G. Road, Gurugram - 122 002, Haryana, INDIA.

Tel. : +91-124-4223207-08, 4034205 | Cell : +91-9289351688

Location 1 (Permanent Site Facility)

D-18, Infocity Ph.-II, Sec-33, Gurugram - 122001, Haryana, INDIA.

Tel. : +91-124-4057437 | Cell : +91-9289351688

Email : farelabs@farelabs.com | Website : www.farelabs.com

TEST REPORT

Issued to :

The Green Public School
Muzaffarnagar Road
Bhasana Budhana Muzaffarnagar
Uttar Pradesh, India

J.O. No. : W20250614-109-176
ULR Code : TC5503 25 2 00026251 F
Report Date : 19-06-2025
Sample Receipt Date : 14-06-2025
Account Manager : BD Team 5
Credit Manager : Gulab Singh



Customer Provided Information:#

Nature/Name of the Sample

Location

Source of Water

Treatment Type

: **RO Water**
: RO Plant
: Borewell
: RO Treatment

Laboratory Provided Information:

Sample Quantity & Packaging

Test started on

Test Completed

Method of Sampling

Date of Sampling

Sample Picked by

: 1Litre x 3, Pet Bottle
: 14-06-2025
: 19-06-2025
: FL/SOP/B/D-1
: 14-06-2025
: Mr. Awdhesh (FARE LABS Representative) at the premises of The Green Public School



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012	Method
Organoleptic & Physical Parameters					
1	Colour	Hazen	1	5 Max.	IS 3025 (P-4)
2	Odour	--	Agreeable	Agreeable	IS 3025 (P-5)
3	Total Dissolved Solids	mg/L	150	500 Max.	IS 3025 (P-16)
4	Turbidity	NTU	0.32	1.0 Max.	IS 3025 (P-10)
5	pH value	--	6.88	6.5-8.5	IS 3025 (P-11)
Chemical Analysis					
1	Calcium (as Ca)	mg/L	10.4	75 Max.	IS 3025 (P-40)
2	Chloride (as Cl)	mg/L	31.99	250 Max.	IS 3025 (P-32)
3	Residual Free Chlorine	mg/L	BLQ, (LOQ-0.1)	0.2 Min.	APHA 24 th ED.
4	Total Alkalinity (as CaCO ₃)	mg/L	85	200 Max.	IS:3025 (P-23)
5	Total Hardness (as CaCO ₃)	mg/L	46	200 Max.	IS 3025 (P-21)
Metal Analysis					
1	Iron (as Fe)	mg/L	BLQ, (LOQ-0.05)	1.0 Max.	FL/SOP/12-01

[Signature]

PRINCIPAL
The Green Public School
Budhana Muzaffarnagar

[Signature]
Manager
The Green Public School
Budhana (MZN.)

[Signature]

Authorised Signatory
Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARELABS Pvt. Ltd. within 7 days of issue of this report.

Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.

FARELABS

Science | Technology | Innovation

FARE LABS Private Limited (Testing Division)

Location 1 (Permanent Facility)

L-17/3, DLF Phase-II, IFFCO Chowk,

M.G. Road, Gurugram - 122 002, Haryana, INDIA.

Tel. : +91-124-4223207-08, 4034205 | Cell : +91-9289351688

Location 1 (Permanent Site Facility)

D-18, Infocity Ph.-II, Sec-33, Gurugram - 122001, Haryana, INDIA.

Tel. : +91-124-4057437 | Cell : +91-9289351688

Email : farelabs@farelabs.com | Website : www.farelabs.com

TEST REPORT

Issued to :

The Green Public School
Muzaffarnagar Road
Bhasana Budhana Muzaffarnagar
Uttar Pradesh, India

J.O. No. : W20250614-109-176
ULR Code : TC5503 25 2 00026251 F
Report Date : 19-06-2025
Sample Receipt Date : 14-06-2025
Account Manager : BD Team 5
Credit Manager : Gulab Singh



Customer Provided Information:#

Nature/Name of the Sample

Location

Source of Water

Treatment Type

: RO Water

: RO Plant

: Borewell

: RO Treatment

Laboratory Provided Information:

Sample Quantity & Packaging

Test started on

Test Completed

Method of Sampling

Date of Sampling

Sample Picked by

: 1Litre x 3, Pet Bottle

: 14-06-2025

: 19-06-2025

: FL/SOP/B/D-1

: 14-06-2025

: Mr. Awdhesh (FARE LABS Representative) at the premises of The Green Public School



TC - 5503

Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012	Method
Microbiological Analysis					
1	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	IS 15185
2	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	IS 15185

BLQ= Below Limit of Quantification; LOQ= Limit of Quantification

Note: FL/SOP/12-01, Based on APHA 24th Ed.

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Opinion: Selected parameters were asked to perform and they **conforms** as per (IS-10500: 2012) of drinking water for given selected parameters only.

PRINCIPAL
The Green Public School
Budhana Muzaffarnagar

Zohra Akh.
Manager

The Green Public School
Budhana (MZN.)

Authorised Signatory
Dr. Jasarat Ali, Scientist-C